

Annual Drinking Water Quality Report for 2013
Village of Cattaraugus
14 Main Street, Cattaraugus, New York, 14719
Public Water Supply ID# NY0400335

INTRODUCTION

To comply with State regulations, the Village of Cattaraugus will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water quality and awareness of the need to protect our drinking water sources. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Jason Opferbeck, DPW Superintendent at (716) 257-5114. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. The meetings are held on the second Monday of each month at 7:00 PM at the Village Hall, 14 Main Street, Cattaraugus, NY 14719.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Water for the Village of Cattaraugus is being provided primarily by springs, with two auxiliary groundwater wells. The springs are located south of the village in the Town of New Albion at an elevation that allows water to be distributed through the system via gravity. The Mayo Road Springs and Kenyon Hill Springs are located approximately 3 miles south of the village. The Kelley Summit Springs are located off NYS Route 353 approximately 3½ miles southeast of the village. The water passes through two slow sand filtration plants; one that serves the Mayo Road and Kenyon Hill Springs and one that serves the Kelley Summit Springs. Water is disinfected using liquid chlorine at the filter sites. The production capacity of the springs is over 200 gallons per minute. The Cobo Well is located south of the village, is 44 feet deep in a gravel aquifer and can produce up to 250 gallons per minute. Disinfection is by liquid chlorine. This well is rarely used in the summer months to supplement our springs. The Blackmar Well is also located south of the village, is 140 feet deep in a sand and gravel aquifer and can produce up to 230 gallons per minute. However, we stopped using this well in October 2012 due to the detection of a chemical contaminant and now it is only to be used on an emergency basis. An air stripper treatment unit was installed in 2013 to remove the low levels of Methylene Chloride if necessary.

Our water system serves approximately 1,185 people through 500 service connections.

In 2003, the NYS DOH completed a source water assessment for our water system, based on available information. Possible and actual threats to the drinking waters sources were evaluated. The source water assessment includes a susceptibility ratings based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells and springs. The susceptibility rating is an estimate of the potential contamination of the source water. It does not mean that the water delivered to consumers is, or will become contaminated. See section "ARE THERE CONTAMINANTS IN MY DRINKING WATER?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water sources are springs and wells. Based on available information, the source water assessment has rated the susceptibility to contamination for our springs as medium to protozoan and pesticide

contamination. These ratings are due to the pasture and row crop land covers in the assessment areas. However, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards.

A copy of these assessments, including a map of the assessment areas, can be obtained by contacting us, as noted above.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: coliform bacteria, inorganic compounds, nitrate, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Cattaraugus County Health Department at (716) 373-8050.

Table of Detected Contaminants

<i>Contaminant</i>	<i>Violation Yes/No</i>	<i>Date of Sample</i>	<i>Level Detected (Range)</i>	<i>Unit Measurement</i>	<i>MCLG</i>	<i>Regulatory Limit (MCL, TT or AL)</i>	<i>Likely Source of Contamination</i>
Disinfectant							
Chlorine Residual	No	2013	Avg. = .82 (.25 - 1.75)	mg/l	N/A	MRDL=4	Water additive used to control microbes.
Microbiological Contaminants							
Turbidity – Filtered ¹	No	4/1/13	2.56	NTU	n/a	TT= ≤ 5.0 NTU	Soil runoff.
Turbidity – Filtered ¹	YES	3/2013 4/2013	87.1% < 1.0 94.6 % < 1.0	NTU	n/a	TT = 95% of samples ≤ 1.0 NTU	Soil runoff.
Distribution Turbidity ²	No	2013	100% < 0.1	NTU	N/A	TT= ≤ 5.0 NTU	Soil runoff.
Inorganic Contaminants							
Arsenic	No	8/8/11	High = 4.6 (ND - 4.6)	ug/l	10	N=N/A	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	No	8/8/11	High = 240 (73 – 240)	ug/l	2000	MCL=2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Copper ³	No	8/8/12	68 (30 - 68)	ug/l	1300	AL=1300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead ⁴	No	8/8/12	2.6 (ND-4)	ug/l	0	AL=15	Corrosion of household plumbing; erosion of natural deposits.
Nickel	No	8/8/11	High = 6 (ND – 6)	ug/l	0	None set	Erosion of natural deposits.
<i>Contaminant</i>	<i>Violation Yes/No</i>	<i>Date of Sample</i>	<i>Level Detected (Range)</i>	<i>Unit Measurement</i>	<i>MCLG</i>	<i>Regulatory Limit (MCL, TT or AL)</i>	<i>Likely Source of Contamination</i>

Nitrate	No	3/19/13	High = 5.71 (<1.0 – 5.71)	mg/l	10	MCL=10	Runoff from fertilizer use; leaching from septic tanks, Sewage; erosion of natural deposits.
Volatile Organic Contaminants							
Methylene Chloride •Blackmar Well	YES	2012	High = 13 (10 – 13)	ug/l	0	MCL=5	Discharge from pharmaceutical and chemical factories.
Disinfection By-Products							
Total Haloacetic Acids	No	2013	Avg. = 4.5 (<1 – 8.4)	ug/l	60	MCL=60	By-product of drinking water disinfection needed to kill harmful organisms.
Total Trihalomethanes	No	2013	Avg. = 8.6 (4.2 - 13)	ug/l	N/A	MCL=80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Radiological Contaminants							
Gross Alpha •Cobo Well	No	2009	Avg. = 1.47 (1.1 – 1.84)	pCi/L	0	MCL=15	Erosion of natural deposits.
•Blackmar Well	No	2009	Avg. = 1.31 (.61 – 2.0)				
Radium 226 •Cobo Well	No	2009	Avg. = .40 (.15 - .65)	pCi/L	0	MCL=5	Erosion of natural deposits.
•Blackmar Well	No	2009	Avg. = .46 (.34 - .58)				
Radium 228 •Cobo Well	No	2009	Avg. =.35 (.26 - .44)	pCi/L	0	MCL=5	Erosion of natural deposits.
•Blackmar Well	No	2009	Avg. = .08 (.02 - .13)				

Notes

1 – Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. State regulations require that turbidity must always be below 5.0 NTU. The regulations require that 95% of the turbidity samples collected have measurements below 1.0 NTU. The level recorded in March and April was not within the acceptable range allowed and did constitute a treatment technique violation.

2 – All of our monthly distribution turbidity measurements were < 0.1 NTU. This value is below the turbidity standard of 5 NTU assigned to our system.

3 - The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, ten samples were collected at your water system and the 90th percentile value was the second highest value, 68 ug/l. The action level for copper was not exceeded at any of the sites tested.

4 - The 90th percentile level for lead was 2.6 ug/l. None of the ten sites exceeded the action level of 15 ug/l.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

In 2012, routine testing of the Blackmar Well determined that methylene chloride is present in excess of the USEPA established MCL of 5 ug/l (parts per billion). As such we stopped using the Blackmar Well as soon as the results were confirmed. Due to the low concentration and limited exposure, the health department does not classify this as a serious health risk. However, federal regulations require that we provide you with this statement: "Some people who drink water containing methylene chloride in excess of the MCL, over many years, could have liver problems and may have an increased risk of getting cancer." In 2013, NYDEC developed a plan and installed treatment for the methylene chloride. However, at this time the Blackmar well is to be used only on an emergency basis.

Nitrate was detected at the Mayo Road Springs at 5.71 mg/l. Although this level is below the MCL it is greater than one-half of the MCL. Therefore, we are required to present the following information on nitrate in drinking water. "Nitrate in drinking water at levels above 10 mg/l is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider."

We are also required to provide the following information on lead in drinking water even though none of the ten sample sites exceeded the established action limit. "If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The Village of Cattaraugus is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>."

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

On April 11, 2013 and April 12, 2013, the chlorine residual at the Mayo Road filter plant was recorded as being less than 0.2 mg/l for greater than 4 hours. This was a violation of 10 NYCRR Part 5-1.30(b)(2). In addition we received a violation for failing to make state notification when the free chlorine residual fell below 0.2 mg/l. Also, we exceeded the allowable filtered water turbidity at the Mayo Road filter plant during this event. 13% of the turbidity readings taken during April and almost 6% in May exceeded the performance standard value of 1.0 NTU. Required public notices were distributed to our customers in reference to the above violations.

Be advised that we are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the fourth quarter of 2013 we failed to monitor for Total Organic Carbon (TOC) which was also a monitoring violation. However, the other three quarterly results in the year were below the established level allowed. The next TOC sample will be collected during 1/1/14 – 3/31/14.

There is nothing you need to do at this time. If a situation was to ever arise where the water is no longer safe to drink, we would notify you immediately in accordance with federal and state regulations.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.
- ◆ You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:
 - ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
 - ◆ Turn off the tap when brushing your teeth.
 - ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
 - ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this past year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. However, we are pleased to inform you that we applied for a \$600,000 grant from the NYS Office of Community Renewal, and were notified recently that it has been awarded. Consequently we are currently working with our engineer, health department, and financial advisor to design and complete certain improvements in 2014. These may include reconstructing the Kelley Summit Springs, constructing a new transmission line for the Kenyon Hill Springs, and installing a modern metering system for all water customer services. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.